



STERILIZING SERVICES LTD

WATER TANKS & SYSTEMS CLEANED & DISINFECTED

BATHING WATER QUALITY REPORT

Report Date: 13.12.22

Client: YMCA Newark/Sherwood

Date Taken: 07.12.22

Site: Balderton Lake

Date Received: 07.12.22

Sample No.	Location	Total Coliforms Per100mls	E.Coli Per 100mls	Enterococci cfu/100mls
1546949	Lake Sample	45	45	5

Guide Levels in accordance with The Water Supply (Water Quality) Regulations 2002 – Regulations 6.21

Analysing Laboratory: UKAS Accredited Laboratory No. 2450

Test Methods in accordance with The Microbiology of Drinking Water (2002)

Mandatory Guidelines

Discretionary Guidelines

Coliforms 10000
E. Coli 2000
Enterococco No Limit

Coliforms 500
E. Coli 100
Enterococci 100

No. Samples Taken: 1

Authorized Signature: